AUC
Alberta Utilities Commission

310-4AUC
1-833-511-4AUC
www.auc.ab.ca

1400, 600 Third Avenue S.W.
Calgary, Alberta
T2P 0G5

Power Plant
Approval 29553-D01-2024

	October 30, 2024
Brox Energy Operations Inc. 2.5-Megawatt Natural Gas-Fired Power Plant	Proceeding 29553 Application 29553-A001

Brox Energy Operations Inc., by Application 29553-A001, registered on October 23, 2024, applied to the Alberta Utilities Commission for approval to construct and operate a 2.5-megawatt (MW) natural gas-fired power plant, located within the Convega Energy Ltd. Kirkwall gas plant site.

Brox Energy Operations Inc. has provided information respecting the nature, extent, location, ownership and the timing of the power plant. Brox Energy Operations Inc. has confirmed that it will fulfil the requirements of all other agencies with jurisdiction over the project. Brox Energy Operations Inc. has confirmed that the power plant will comply with Rule 012: *Noise Control*, no other person is directly and adversely affected by the power plant, and no adverse environmental impact will be caused by the power plant.

The Commission, pursuant to Section 11 of the *Hydro and Electric Energy Act*, approves the application and grants an approval to Brox Energy Operations Inc. to construct and operate the power plant, subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The power plant shall be located in Legal Subdivision 7, Section 29, Township 27, Range 5, west of the Fourth Meridian, as further described in the application.

2. The power plant shall consist of two 1XQ1250G Caterpillar natural gas engines, with a total generating capability of 2.5 MW, and as further described in the application.

3. Unless otherwise authorized by the Commission, construction of the power plant shall be completed by November 4, 2024.

4. Brox Energy Operations Inc. shall notify the Commission within 30 days of completing the power plant.

5. Brox Energy Operations Inc. shall obtain Commission approval prior to making any substantive changes to the power plant or substantially varying the design or specifications of the power plant from what was stated in the application or what the Commission has approved.

6. This approval is not transferable unless approved by the Commission.

The Commission may cancel or suspend this approval, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act*, or may review this approval, in whole or in part upon its own motion, or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

The Commission may, no later than 60 days from the date of this approval and without notice, correct typographical, spelling and calculation errors and other similar types of errors and post the corrected approval on its website.

Alberta Utilities Commission

(original signed by)

Danielle Glover
Director – Gas Facilities and Technical Assessment, Facilities Division
On behalf of the Alberta Utilities Commission