AUC
Alberta Utilities Commission

310-4AUC
1-833-511-4AUC
www.auc.ab.ca

1400, 600 Third Avenue S.W.
Calgary, Alberta
T2P 0G5

Power Plant
Approval 30814-D02-2026

Appendix 1 to Decision 30814-D01-2026	June 26, 2026
2783294 Alberta Ltd. 9.798-Megawatt Schuler Gas-Fired Power Plant	Proceeding 30814 Application 30814-A001

2783294 Alberta Ltd., by Application 30814-A001, registered on May 8, 2026, applied to the Alberta Utilities Commission for approval to construct and operate a 9.798-megawatt (MW) thermal power plant, located near the hamlet of Schuler.

Pursuant to sections 11 and 19 of the *Hydro and Electric Energy Act*, the Commission approved the application in Decision 30814-D01-2026,[1] and granted an approval to 2783294 Alberta Ltd., to construct and operate the power plant, subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The power plant shall be located in the northwest quarter of Section 7, Township 16, Range 1, west of the Fourth Meridian, as further described in the application.

2. The power plant shall consist of one 998-kilowatt gas generator and four 2.2-MW generators, with a total generating capability of 9.798 MW, and as further described in the application.

3. The approval is subject to the following condition which has been described in Decision 30814-D01-2026:

    a. Before the second phase of the project commences operations, 2783294 Alberta Ltd. shall implement the noise mitigation measures identified in the noise impact assessment, or alternative measures that provide equal or greater acoustic performance, to ensure the power plant complies with Rule 012: *Noise Control*. On or before the date that the second phase of the project commences operations, 2783294 Alberta Ltd. must file a letter with the Commission detailing the mitigation measures it has implemented.

4. Unless otherwise authorized by the Commission, construction of the power plant shall be completed by January 31, 2027.

5. 2783294 Alberta Ltd. shall notify the Commission within 30 days of completing the power plant.

[1] Decision 30814-D01-2026: 2783294 Alberta Ltd. – Schuler Gas-Fired Power Plant, Proceeding 30814, Application 30814-A001, June 26, 2026.

6. 2783294 Alberta Ltd. shall obtain Commission approval prior to making any substantive changes to the power plant or substantially varying the design or specifications of the power plant from what was stated in the application or what the Commission has approved.

7. This approval is not transferable unless approved by the Commission.

The Commission may cancel or suspend this approval, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act*, or may review this approval, in whole or in part upon its own motion, or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act.*

The Commission may, no later than 60 days from the date of this approval and without notice, correct typographical, spelling and calculation errors and other similar types of errors and post the corrected approval on its website.

Alberta Utilities Commission

Rita Chan
Director – Power Plants, Facilities Division
On behalf of the Alberta Utilities Commission